

U-Line® Factory Sealed 20 Amp Malleable Iron Receptacles

Explosionproof, Dust-Ignitionproof

125 Vac, 20 Amp, 1 HP; 250 Vac, 20 Amp, 2 HP. Dead-Front Safety Construction.

Class I, Division 1 Groups B⁺, C, D
 Class I, Division 2 Groups B, C, D
 Class II, Division 1 and 2 Groups F, G
 Class III
 NEMA 3, 3R

Malleable Iron Receptacle and Malleable Iron Mounting Box

Type	Wire/Pole	Hub Size (Inches)	Catalog Number	
			125 Vac, 1 HP 	250 Vac, 2 HP 

Single Gang — Class I, Group B

Class I, Division 1 and 2 Groups B, C, D; Class II, Division 1 and 2 Groups F, G; Class III

These models have separate factory sealed chamber—suitable for Class I, Group B as well as Class I, Groups C and D, Class II, Groups F⁺, G and Class III. No external seals required.



Dead-End

Feed-Thru

Dead-End	2W, 3P	1/2	EFSCB150-2023M	EFSCB150-20232M
		3/4		
Feed-Thru	2W, 3P	1/2	EFSCB175-2023M	EFSCB175-20232M
		3/4		



Separate Sealing Chamber
Factory Sealed

Single Gang

Class I, Division 1 and 2 Groups B⁺, C, D; Class II, Division 1 and 2 Groups F, G; Class III

Suitable for use in Class I, Division 1, Group B when used with external seals. †



Dead-End

Feed-Thru

Dead-End	2W, 3P	1/2	EFS150-2023M	EFS150-20232M
		3/4		
		1		
Feed-Thru	2W, 3P	1/2	EFSC150-2023M	EFSC150-20232M
		3/4		
		1		

EFS175-2023M	EFS175-20232M		
		EFS110-2023M	EFS110-20232M
		EFSC175-2023M	EFSC175-20232M
EFSC110-2023M	EFSC110-20232M		

Two Gang

Class I, Division 1 and 2 Groups C, D; Class I, Division 2, Groups B, C, D; Class II, Division 1 and 2 Groups F, G; Class III.



Dead-End

Feed-Thru

Dead-End	2W, 3P	1/2	EFS250-2023M	EFS250-20232M
		3/4		
		1		
Feed-Thru	2W, 3P	1/2	EFSC250-2023M	EFSC250-20232M
		3/4		
		1		

EFS275-2023M	EFS275-20232M		
		EFS210-2023M	EFS210-20232M
		EFSC275-2023M	EFSC275-20232M
EFSC210-2023M	EFSC210-20232M		

Malleable Iron Replacement Receptacle Only



2W, 3P

Spring door replacement assembly (iron)

EFSR-2023M

EFSR-20232M

ULSCM

† Seals (not furnished—see Fittings Section) must be placed within 2 inches from each conduit opening. Seals are not required in Class I, Division 2 locations.

♦ Shaded area indicates items suitable for Class I, Group B, C and D; Class II, Groups F, G; and Class III.