

Recall Alert

U.S. Consumer Product Safety Commission

Office of Information and Public Affairs

Washington, DC 20207

May 9, 2007
Alert #07-546

Cooper Lighting Emergency Lights Recalled, Could Fail to Illuminate in an Emergency

The following product safety recall was voluntarily conducted by the firm in cooperation with the CPSC.

Name of Product: Contractor's Choice FasTest™ High Capacity Emergency Lighting Units

Units: About 3,200

Distributor: Cooper Lighting Inc., of Houston, Texas

Hazard: A circuit board in the light could malfunction, preventing the lights from illuminating in the event of a power failure. This could result in a failure to provide adequate lighting to guide building occupants to an exit in the event of an emergency.

Incidents/Injuries: None reported.

Description and Models: The CC7NCSD Contractor's Choice FasTest™ High Capacity Emergency Lighting Unit is an emergency light installed in commercial buildings. The recalled lights have one of the following model numbers written on the inside of the removable front cover:

- CC7NCSD - CC7NCSD0 - CC7NCSD0BK - CC7NCSD0TDM - CC7NCSD1MRT
- CC7NCSD208SM - CC7NCSD214 - CC7NCSD216 - CC7NCSD216TDM
- CC7NCSD219 - CC7NCSD245 - CC7NCSD279SM - CC7NCSD279SMBK
- CC7NCSD279SMSQ - CC7NCSD279SMTDM - CC7NCSD279SMV
- CC7NCSD270TM - CC7NCSD279V - CC7NCSD208SMSQ - CC7NCSDAV
- CC7NCSDSQ - CC7NCSDBK - CC7NCSDMRT - CC7NCSDMRT2142TDM
- CC7NCSDMRT2142V - CC7NCSDMRTV - CC7NCSDSQ245 - CC7NCSDMRT2142
- CC7NCSDSQTDM - CC7NCSDTDM - CC7NCSD208SMSQ

Only products with date codes between 12-2005 and 03-2007 are subject to the recall. The date code appears on the circuit board next to the battery pack and is depicted as MM-YYYY-WW. For example, a product manufactured in the third week of August would have the date code "08-2006-03."

Sold at: Authorized distributors nationwide from February 2006 through March 2007 for about \$200. Authorized distributors resell and install the lights for commercial end users in facilities such as hotels and office buildings.

Manufactured in: China

Remedy: Cooper Lighting is contacting customers directly and is providing a free replacement product.

Consumer Contact: For additional information, contact Cooper Lighting at (800) 954-7228, between 8 a.m. and 5 p.m. ET, Monday through Friday, or go to the firm's Web site at www.cooperlighting.com



[Send the link for this page to a friend!](#) The U.S. Consumer Product Safety Commission is charged with protecting the public from unreasonable risks of serious injury or death from more than 15,000 types of consumer products under the agency's jurisdiction. Deaths, injuries and property damage from consumer product incidents cost the nation more than \$800 billion annually. The CPSC is committed to protecting consumers and families from products that pose a fire, electrical, chemical, or mechanical hazard. The CPSC's work to ensure the safety of consumer products - such as toys, cribs, power tools, cigarette lighters, and household chemicals - contributed significantly to the decline in the rate of deaths and injuries associated with consumer products over the past 30 years.

To report a dangerous product or a product-related injury, call CPSC's hotline at (800) 638-2772 or CPSC's teletypewriter at (800) 638-8270, or visit CPSC's web site at www.cpsc.gov/talk.html. To join a CPSC email subscription list, please go to <https://www.cpsc.gov/cpsclist.aspx>. Consumers can obtain this release and recall information at CPSC's Web site at www.cpsc.gov.